



FOUNDATION PLAN SCALE: 1/8" = 1'-0"



## FOUNDATION/FIRST FLOOR NOTES:

- I. ALL DIMENSIONS AND ELEVATIONS ON THE STRUCTURAL PLANS ARE FOR GENERAL INFORMATION ONLY AND SHALL BE VERIFIED BY THE CONTRACTOR WITH THE ARCHITECTURAL DRAWINGS BEFORE CONSTRUCTION BEGINS. ANY DISCREPANCIES SHALL BE BROUGHT TO THE ATTENTION OF THE ARCHITECT AND ENGINEER IMMEDIATELY.
- 2. SEE SHEETS SI.O AND SI.I FOR STRUCTURAL GENERAL NOTES AND ABBREVIATIONS. SEE SHEET S3.0 FOR TYPICAL CONCRETE AND FOUNDATION DETAILS.
- 3. SLAB-ON-GRADE SHALL BE 4" THICK CONCRETE REINFORCED WITH #4 @ 16" O.C. EACH WAY, U.O.N. REFER TO ARCHITECTURAL DRAWINGS FOR ADDITIONAL INFORMATION REGARDING SUB-GRADE MOISTURE BARRIER AND ELEVATIONS, ETC.
- 4. FOR SLAB-ON-GRADE JOINTS, SEE DETAIL 2/S3.O.
- 5. WHERE NEW CONCRETE IS CAST AGAINST EXISTING CONCRETE FOUNDATIONS, DRILL AND EPOXY #4 DOWELS BY 3'-O" LONG TO LAP WITH THE NEW FOOTING LONGITUDINAL REINFORCING. PROVIDE 5" MINIMUM EPOXY EMBEDMENT INTO THE EXISTING CONCRETE.
- 6. ALL WOOD BEARING ON UNPROTECTED CONCRETE OR MASONRY, EXPOSED TO WEATHER, OR WITHIN 8" OF FINISHED GRADE SHALL BE PRESSURE-TREATED, U.O.N.
- 7. FOR SILL PLATE ANCHOR BOLT LAYOUT TO CONCRETE FOUNDATION WALLS AND SLABS, SEE DETAIL 1/S4.0.
- 8. ALL BEARING/SHEAR WALLS SHALL BE 2x6 @ 16" O.C., U.O.N.
- 9. POSTS INDICATED ARE ABOVE THIS LEVEL. ALL POSTS NOT SPECIFIED SHALL BE (2) 2x U.O.N. SOLID SAWN MEMBERS OF EQUIVALENT SIZE MAY BE SUBSTITUTED FOR BUILT-UP MEMBERS (SUCH AS A 4x6 FOR (3) 2x4).
- 10. Fx.x INDICATES SPREAD FOOTING TYPE, SEE 12/S3.0 FOR SCHEDULE.
- II. SM-X INDICATES SHEAR WALL AT THIS LEVEL. SEE SHEAR WALL SCHEDULE 8/54.0 FOR SHEATHING, BLOCKING, NAILING, AND ANCHOR BOLT REQUIREMENTS. ALL EXTERIOR WALLS SHALL BE SHEATHED PER SW-6 CRITERIA U.O.N.
- 12. HDUX INDICATES HOLDOWN TO CONCRETE FOUNDATION WALLS OR FOOTINGS. SEE 12/S4.0 FOR HOLDOWN DETAIL. USE MIN. (2) 2x POST U.O.N.
- 13. CONTRACTOR TO PROVIDE SHORING OF (E) GLULAM BEAM (END REACTION = 10,000# TOTAL LOAD) AND (E) FLOOR AND ROOF FRAMING UNTIL NEW CONCRETE STEM WALL AND FOOTING BELOW HAVE ATTAINED FULL DESIGN STRENGTH.

## LEGEND:



(FXX) INDICATES SPREAD FOOTING SEE 12/53.0 FOR SCHEDULE

INDICATES FOOTING



INDICATES FOUNDATION WALL, WOOD BEARING WALL OR SHEAR WALL ABOVE FLOOR FRAMING

INDICATES FOOTING



INDICATES 8" CMU WALL. SEE GENERAL NOTES AND DETAILS FOR REINFORCING REQUIREMENTS



NON-SHEAR WALL ABOVE.

INDICATES NON-BEARING/



**1511 THIRD AVENUE SUITE 323** SEATTLE, WA 98101 TEL 206.957.3900 FAX 206.957.3901 www.quantumce.com

SEAL:



PROJECT:

## RAM NIWAS CHURCH

AUBURN, WA 98001

OWNER: SATGURU RAM SINGH SATSUNGH Contact Person: Mr. Sukhdev Aulakh Contact Phone: (425) 255-6476

SHEET NOTES:

	PERMIT	SUBMITTAL		8/2/11	
NO.		DESCRIPTION		DATE	BY
ISSUES:		REVISIONS:			
P.M.			DPF		
P.E.			WI		
DRAWN BY:			SC		
SCALE:			AS SHOWN		

**FOUNDATION** PLAN

SHEET NO.

JOB NO.

SHEET TITLE:

S2.0R REVIE.DIN

8/2/2011

11136.01