



0 5 10 20 SCALE 1'' = 20'

NOTES:

- 1. ALL PIPE SLOPES NOTED ARE FT/FT.
- 2. ALL SANITARY SEWER MANHOLES ARE STATIONED TO CENTER OF STRUCTURE
- 3. ALL PVC PIPE SHALL BE SDR-35 UNLESS OTHERWISE NOTED
- 4. SIDE SEWERS TO BE INSTALLED PER C.O.A. STD. DTL. SEWER-01 AND SEWER-02
- 5. SEWER STUBS TO BE MARKED USING A PAINTED 2"x4" MARKED "SEWER"
- 6. WATER SERVICE STUBS TO BE MARKED USING A PAINTED 2"x4" MARKED "WATER"
- 7. ALL SIDE SEWERS ARE STATIONED FROM THE NEAREST DOWNSTREAM MANHOLE
- 8. ALL WATER METERS SHALL BE 🛃 INCH PER C.O.A. STANDARD DETAIL WATER-13, 1" MINIMUM SERVICE LINE BETWEEN MAIN AND 1 INCH METER.
- 9. SANITARY SEWER MANHOLES SHALL BE EQUIPPED WITH A SOLID LOCKING LID WITH THE WORDS "CONFINED SPACE - PERMIT REQUIRED" CAST INTO LID.

