



**CONSTRUCTION NOTES**

- ① INSTALL CONCRETE PAD, FOUNDATION, TYPE 1 JUNCTION BOX, DAVIT-STYLE LUMINAIRE STANDARD AND FIXTURE PER CITY OF AUBURN STANDARD DETAILS TRAFFIC-43, 44, 46 AND 50.
- ② INSTALL TYPE I JUNCTION BOX PER CITY OF AUBURN STANDARD DETAIL TRAFFIC 50.
- ③ EXTEND CONDUIT AND CONDUCTORS TO NEAREST JUNCTION BOX IN KERSEY 3 PLAT AND SPLICE CONDUCTORS TO EXISTING LIGHTING CIRCUIT.

**LUMINAIRE SCHEDULE**

LUM. NO.	CIRCUIT NO.	LOCATION	OFFSET (FEET)	LAMP WATTAGE	MAST ARM (FEET)	MOUNTING HGT. (FT.)	POLE TYPE	LUMINAIRE
20	C	WESLEY AVE. SE 10+71	19.0' RT.	100	8'	30'	DAVIT	M2AC10S3MIGMC32
21	C	CUL DE SAC A 0+37	19.0' RT.	100	8'	30'	DAVIT	M2AC10S3MIGMC32
22	C	CUL DE SAC A 1+55	23.0' RT.	100	8'	30'	DAVIT	M2AC10S3MIGMC32
23	KERSEY*	53RD ST. SE 0+61	19.0' RT.	100	8'	30'	DAVIT	M2AC10S3MIGMC32
24	KERSEY*	53RD ST. SE 2+08	19.0' RT.	100	8'	30'	DAVIT	M2AC10S3MIGMC32
25	KERSEY*	53RD ST. SE 3+34	19.0' RT.	100	8'	30'	DAVIT	M2AC10S3MIGMC32
26	KERSEY*	54TH ST. SE 0+77	19.0' LT.	100	8'	30'	DAVIT	M2AC10S3MIGMC32
27	KERSEY*	54TH ST. SE 2+30	19.0' LT.	100	8'	30'	DAVIT	M2AC10S3MIGMC32
28	KERSEY*	54TH ST. SE 3+84	19.0' LT.	100	8'	30'	DAVIT	M2AC10S3MIGMC32

\* EXISTING KERSEY 3 CIRCUIT

**WIRING SCHEDULE**

RUN NO.	CONDUIT	CONDUCTORS	REMARKS
①	2" SCHEDULE 40 PVC	2-#6,1-#6 BARE	
②	2" SCHEDULE 80 PVC	2-#6,1-#6 BARE	
⑨	2" SCHEDULE 40 PVC	PULL STRING	FUTURE USE

**GENERAL NOTES**

- 1. ALL WORK SHALL BE IN ACCORDANCE WITH THESE PLANS, THE CITY OF AUBURN CONSTRUCTION STANDARDS, THE WASHINGTON STATE DEPARTMENT OF TRANSPORTATION (WSDOT) STANDARD SPECIFICATIONS FOR ROAD, BRIDGE AND MUNICIPAL CONSTRUCTION (CURRENT EDITION), AND THE WSDOT STANDARD PLANS.

**LEGEND**

- TYPE M-C-III HPS LUMINAIRE, ARM AND ALUMINUM DAVIT STYLE POLE PER CITY OF AUBURN STANDARD DETAIL TRAFFIC-44
- CONCRETE PAD LIGHT BASE AND TYPE I LOCKING JUNCTION BOX PER STANDARD DETAILS TRAFFIC-43 AND 50
- PVC CONDUIT (SEE WIRING SCHEDULE)
- TYPE I LOCKING JUNCTION BOX PER STANDARD DETAIL TRAFFIC-50
- SERVICE CABINET SHALL BE INSTALLED PER COA STANDARD DETAIL TRAFFIC-45
- WIRING NOTE
- CONSTRUCTION NOTE

RECORD DRAWING CERTIFICATION  
 THESE DRAWINGS CONFORM TO THE CONTRACTOR'S CONSTRUCTION RECORDS.  
 BY \_\_\_\_\_ DATE \_\_\_\_\_  
 TITLE/POSITION: \_\_\_\_\_  
 CONFIRMED BY CITY: \_\_\_\_\_ DATE \_\_\_\_\_

PROJECT REF: FAC07-0016  
 THESE PLANS ARE APPROVED FOR CONFORMANCE WITH THE CITY OF AUBURN'S ENGINEERING DIVISION REQUIREMENTS.  
 APPROVED BY: *Dennis Solle*  
 DATE APPROVED: 5/15/13

**Traffex**  
 NORTHWEST TRAFFIC EXPERTS  
 11410 NE 124th St., #590, Kirkland, WA 98034  
 Phone: 425.522.4118 Fax: 425.522.4311

Call before you Dig.  
 1-800-424-5555  
 UNDERGROUND SERVICE (USA)

NOTE:  
 EXISTING UTILITY LOCATIONS SHOWN HEREON ARE APPROXIMATE ONLY IT SHALL BE THE CONTRACTOR'S RESPONSIBILITY TO DETERMINE THE EXACT VERTICAL AND HORIZONTAL LOCATION OF ALL EXISTING UNDERGROUND UTILITIES PRIOR TO COMMENCING CONSTRUCTION. NO REPRESENTATION IS MADE THAT ALL EXISTING UTILITIES ARE SHOWN HEREON. THE ENGINEER ASSUMES NO RESPONSIBILITY FOR UTILITIES NOT SHOWN OR UTILITIES NOT SHOWN IN THEIR PROPER LOCATION. CALL BEFORE YOU DIG: 1-800-424-5555.

OWNER: LAKELAND HILLS ESTATES LLC  
 PROJECT: LAKELAND HILLS  
 SHEET CONTENT: ILLUMINATION PLAN

DESIGNED BY: VJG  
 DRAWN BY: VJG  
 CHECKED BY: LDH

LEGEND  
 5 VJG LDH 5-9-13  
 4 CONST. NOTES 1, 2, WIRE NOTE 9, AND LEGEND RESIGN PLAN VJG LDH 3-20-13  
 3 VJG LDH 11-27-12  
 2 ADD LOCKING JOB NOTE, REMOVE CONDUIT VJG LDH 2-27-08  
 1 ADD JOB AND CONNECT TO KERSEY 3 CIRCUIT VJG LDH 2-22-08  
 REV. NO. DESCRIPTION BY CHK DATE

DATE 3/20/13  
 JOB NO. AUBURN  
 DWG NO. 2  
 SHEET 2 OF 2